

The Winter 2018-2019 Full Load Control will be initiated when Dairyland Power Cooperative's System load is expected to obtain seasonal peak conditions. Below are the detailed control times for each load classification subject to participation in FLC events.

Load Description	Control Class / Address	Alert On	Alert Off	Control Start	All Loads Controlled	Restoral Start	All Loads Restored
<b>FULL LOAD CONTROL SCHEDULE</b>							
<b>Alert Devices</b>	<b>Address 511</b>	15:55	20:00	n/a	n/a	n/a	n/a
<b>Small Water Heaters</b>	<b>Class 1A</b>	n/a	n/a	17:00	17:00	20:00	21:00
<b>Large Water Heaters</b>	<b>Class 1B</b>	n/a	n/a	17:00	17:00	22:00	23:00
<b>Dairy Water Heaters</b>	<b>Class 4A</b>	n/a	n/a	17:00	17:00	21:30	22:00
<b>Interruptible Heat</b>	<b>Class 2A, 2B, 2C, 2W</b>	n/a	n/a	17:00	17:00	21:00	22:00
<b>Misc Interruptible Heat</b>	<b>Class 4B</b>	n/a	n/a	17:00	17:00	20:00	20:30
<b>Grain Drying</b>	<b>Class 24</b>	16:40	20:50	16:50	16:50	20:50	20:50
<b>C &amp; I Generators</b>	<b>Classes 5A &amp; AE-1</b>	16:40	20:00	16:50	16:50	20:00	20:00
<b>C &amp; I Peak Alert</b>	<b>Class 5B</b>	16:20	20:00	16:50	16:50	20:00	20:00